

Rule No. 2

DESCRIPTION OF SERVICE

A. Quantities

The utility will endeavor to supply water dependably and safely in adequate quantities to meet the reasonable needs and requirements of customers.

B. Pressures

1. Generally

The utility will endeavor to maintain normal operating pressures of not less than 40 pounds per square inch nor more than 125 pounds per square inch at the service connection, except that during periods of hourly maximum demand the pressure at the time of peak seasonal loads may not be less than 30 pounds per square inch and that during periods of hourly minimum demand the pressure may not be more than 150 pounds per square inch. Variations in pressure under normal operation will not exceed 50% of the average operating pressure. (The average operating pressure will be determined by computing the arithmetical average of at least 24 consecutive hourly pressure readings).

2. Designated Pressure Area.

Certain designated areas, as shown and described on utility's service area map " 'San Jose Water Company' Areas With Special Pressure Conditions", are subject to different conditions than those described in "1" above.

(T)
|
|
(T)

C. Quality

Whenever furnished for human consumption or for domestic uses, the utility will endeavor to provide water that is wholesome, potable, in now way harmful or dangerous to health and, insofar as practicable, free from objectionable odors, taste, color and turbidity.

(To be inserted by utility)

Issued by

(To be inserted by Cal. P.U.C.)

Advice No. 188

Fred R. Meyer

Date Filed Jan 06 1986

Vice President and

Effective Feb 05 1986

Dec. No. _____

Chief Fin. Officer

Resolution No. _____

TITLE