



MATERIAL LIST	
#	DESCRIPTION
1	ANGLE METER STOP, 3/4", MUELLER H-14255 FLR
2	METER, 3/4"
3	CPLG, 3/4" STRAIGHT METER, MUELLER H-10890 MIP
4	VALVE CHECK, 3/4" STD (SWING CHECK-RESILENT SEAT)
5	NIPPLE, CLOSE BRASS, 3/4"
6	BUSHING, STD BRASS, 1" X 3/4"
7	3/4" PIPE, COPPER, TYPE K
8	DETECTOR CHECK
9	CPLG, 90° BEND, 3/4" H-15530 FLR X MIP
10	BUSHING, TAP X 3/4", BRASS STD
11	METER BOX, CHRISTY #B30

MUELLER A-2132-6			
SIZE	A	B	TAP
4"	16 1/2"	15 5/8"	1"
6"	22 1/2"	20 1/8"	1 1/2"
8"	25"	23 7/8"	2"
10"	28"	27 5/8"	2"

REVISION	DATE	CK	AP	OPS
SAN JOSE WATER COMPANY				
DETECTOR CHECK INSTALLATION				
BY	P. JOCHIM	<i>P. Jochim</i>		OPERATIONS
DATE	15 NOV '04	<i>[Signature]</i>		ENGINEERING
CK	ELM	<i>[Signature]</i>		REGISTERED ENGINEER
BY	SCALE	NONE		REF. NOS. D-5-629
				DWG. NO. FS-DC