



TAPPING SCHEDULE		
PIPE	PIPE CONNECTION	SIZE
STEEL	* SDL, SSCC, (THRU 10 3/4") ** WELD CPLG (ALL OTHERS)	NOM. DIA. X 3/4" 3/4"
AC	* SDL, SSCC, (4") * DIR TAP, STOP CORP (6" & OVER)	NOM. DIA. X 3/4" 3/4"
CI & DICL	* DIRECT TAP, CORP STOP	3/4"
PVC	** SDL, PVC	NOM. DIA. X 3/4"

NOTE:
 BLOW OFF MAIN BEFORE INSTALLING AIR VALVE
 ALL CORPS AND ANGLE STOPS TO BE LEFT OPEN

REVISION	DATE	CK	AP	OPS
SAN JOSE WATER COMPANY				
STANDARD 1/2" AIR VALVE INSTALLATION (IN PAVEMENT)				
BY	P. JOCHIM	<i>P. Jochim</i>		REF. NOS.
DATE	15 NOV '04	OPERATIONS		A-13-89B
CK	ELM	<i>William</i>		DWG. NO.
SCALE	SHOWN	ENGINEERING		MAIN-AV pavt
		CHIEF ENGINEER		