



- 1) APPROVED ASSEMBLIES ARE REQUIRED TO HAVE RESILIENT SEATED SHUT-OFF VALVES AND TEST COCKS AS INTEGRAL PARTS OF THE ASSEMBLIES OTHERWISE THE APPROVAL IS VOIDED.
- 2) ASSEMBLY MUST BE ACCESSIBLE FOR TESTING AND MAINTENANCE.
- 3) PROTECTION FROM FREEZE DAMAGE MAY BE REQUIRED IN EXPOSED AREAS.
- 4) NO CONNECTIONS OR TEES WILL BE ALLOWED BETWEEN METER AND ASSEMBLY.

- 5) INSTALLATION AND OPERATION MUST COMPLY WITH STANDARDS SET FORTH BY A.W.W.A. AND ALL FEDERAL, STATE, AND LOCAL LAWS, RULES, REGULATIONS, ORDERS, CODES, AND ORDINANCES.
- 6) THE R.P.P. ASSEMBLY SHALL BE INSTALLED AS CLOSE TO THE METER AS PRACTICAL. ANY DEVIATION FROM THIS METHOD MUST BE APPROVED BY SJWC PRIOR TO INSTALLATION.
- 7) IN NO CASE SHALL THIS ASSEMBLY BE INSTALLED BELOW GRADE WITHIN A VAULT OR IN A PIT.

REVISION	DATE	CK	AP	OPS
SAN JOSE WATER COMPANY				
APPROVED REDUCED PRESSURE PRINCIPLE BACKFLOW PREVENTER INSTALLATION				
BY	P. JOCHIM	<i>[Signature]</i>		REF. NOS.
DATE	7/12/10	OPERATIONS		D-5-652
CK	<i>[Signature]</i>	ENGINEERING		DWG. NO.
BY	SCALE NONE	<i>[Signature]</i>		BK-RPP
		CHIEF ENGINEER		

